


AMENDED TECHNICAL SPECIFICATIONS OF LIFTS

1.	Type	Passenger Lift	
2.	Capacity / Load	8/544 Kg.	
3.	Speed	1.5 Meter / Sec.	
6.	Mode (Operation)	Duplex, (with or without attendant)	
7.	Type of Drive	A.C. VVVF	
9.	Signals & Other Features	a)	Call register indicator at all Floors
		b)	Digital car position indicator in car
		c)	Battery operated alarm bell and Emergency light.
		e)	Fireman's switch
		g)	Over-riding Facility
		h)	Adjustable guide shoes
		i)	Music & hands free press & speak intercom
		j)	Braille Buttons
		k)	Stainless steel Hand rails on all 3 sides at 900 mm height
		l)	Voice synthesizer
		m)	Full height car operating panel
		n)	Vendor's shall specify any additional feature if any
10.	Lift shaft available	2500 mm x 1900mm	
11.	Car Size	Standard as per manufacture and IS.	
12.	Door Operation	Automatic ACVVVF	
13.	Door Frame	Stainless steel Hairline Finish	
14.	Type of Door	Centre opening sliding door, two hour fire rated landing doors, Stainless steel Hairline finish.	
15.	Car enclosure	Stainless steel Hairline finishesEnclosure. The ceiling panel shall be with 4 down lights (CFL Type) in stainless steel panel, Ceiling cabin fan.	



A handwritten signature in blue ink, appearing to be 'Q. Khan'.

Annexure-I

16.	Car Floor	25mm thick stone flooring by client.
17.	Car height	2700mm
18.	Door height	2100mm
19.	Car Entrance	900mm wide or as per NBC guide lines
20.	Machine Room	Gearless Machine M/C Room at Terrace
21.	Power Supply	415 Volts + 10%, 3 Phase 4 wire, 50 Hz A.C. supply.
22.	Safeties	a) Overload Safety device.
		b) Full length infrared curtain (min. 150 criss cross beam)
		c) Automatic Rescue device with maintenance free batteries



Olave

Hindustan Latex Family Planning Promotion Trust (HLFPPT), Noida
Corrigendum-02

Tender No. - HLFPPT/ LKW/ 2015

The revised last date of submission of bids is 02.03.2015 up to 15:00 hrs.

Clarifications on queries received from the bidders:

Sl. No.	Bidder's Query	HLFPPT /HLL Reply
Bidder No.1		
1.	Please clarify that whether service tax is applicable or not and if applicable then who will bear the cost.	All Tendered Rates shall be inclusive of all Taxes & Levies including Service Tax. (Refer clause 37 of GCC(page 42)
2.	Likewise about labourcess?	All Tendered Rates shall be inclusive of all Taxes & Levies including LabourCess. (Refer clause 37 of GCC(page 42)
3.	It is requested to allow class 10 b (II) of mobilization advance	Mobilization Advance shall be paid as per provisions of Clause 10 B (ii) given on page 18 of GCC
4.	It is requested to allow to submit the tender at your Lucknow office.	Bids are to be submitted "The Head Finance, HLFPPT, B-14A, Sector 62, Noida-201307". The last date of submission of Bid is extended from 25.02.2015 to 02.03.2015 up to 15: 00 Hrs. The Bids will be opened on 02.03.2015 at 15: 30 Hrs., in the presence of bidders or their authorized representatives who may choose to attend, in the office of HLFPPT, B-14A, Sector-62 Noida-201307.
5.	Regarding EMD please allow FDR also.	Terms & conditions as per tender remain unchanged.
6.	As already discussed in pre bid please modify the technical specification of LIFT.	Amended Technical Specifications of LIFT attached as Annexure-A.
7.	Please also issue us the drawing through email	Already issued by email
Bidder No.2		
1.	We want to submit the tender in your Lucknow office.	Bids are to be submitted "The Head Finance, HLFPPT, B-14A, Sector 62, Noida-201307".



	The last date of submission of Bid is extended from 25.02.2015 to 02.03.2015 up to 15: 00 Hrs. The Bids will be opened on 02.03.2015 at 15: 30 Hrs., in the presence of bidders or their authorized representatives who may choose to attend, in the office of HLPPT, B-14A, Sector-62 Noida-201307.
2.	Complete 10 B should be applicable. Mobilization Advance shall be paid as per provisions of Clause 10 B (ii) given on page 18 of GCC

Amended terms & conditions:-

Sr. No.	Para/ Ref	Existing provisions	Amended provisions
1	2.3.8 (iii) bEMD/ Bid Security	The EMD will be in the form of a bank guarantee from a scheduled commercial bank in India. The format of the bank guarantee shall be as per Form C. Bank guarantees should be irrevocable and operative for a period as mentioned in Notice inviting Bid. The Bid Security shall be endorsed/pledged in favour of HLPPT, B-14A, Sector -62 Noida-201307 and should be valid for a period of six months from date of submission of bids and shall be submitted in a separate envelope super-scribed "Bid Security for Construction of HLPPT Office Building at Lucknow"	The EMD will be in the form of a bank guarantee from a scheduled commercial bank in India or Demand Draft payable to HLPPT, payable at Noida from a scheduled commercial Bank in India. The format of the bank guarantee shall be as per Form C. Bank guarantees should be irrevocable and operative for a period as mentioned in Notice inviting Bid. The Bid Security shall be endorsed/pledged in favour of HLPPT, B-14A, Sector -62 Noida-201307 and should be valid for a period of six months from date of submission of bids and shall be submitted in a separate envelope super-scribed "Bid Security for Construction of HLPPT Office Building at Lucknow"



Amendments in CIVIL BOQ (VOL. IV):

Sr. No.	BOQ Page no.	Item no.	DSR Code no./Ref:	Amended Description of items	Qty.	Unit	Rate in Rs.	Amount in Rs. (in figures)	Amount in Rs. (in words)
1	5	11	Derived from 2.34 & 2.35	Diluting and injecting chemical emulsion for Post-Constructional anti-termite treatment (including the cost of chemical emulsion-Chlorpyrifos/ Lindane emulsifiable concentrate of 20%):					
			2.35.1	Along external wall where the apron is not provided using chemical emulsion @ 7.5 litres / sqm of vertical surface of the substructure to a depth of 300 mm including excavation channel along the wall & rodding etc. Complete.					
			2.35.1.1	With Chlorpyrifos / Lindane E.C 20% with 1% concentration.	100.00	metre			
2	23	8	11.41	Providing & Laying vitrified floor tiles in different sizes (thickness to be specified by the manufacturer) with water absorption's less than 0.08% and confirming to IS : 15622 of approved make in all colours and shades, laid on 20mm thick cement mortar 1:4 (1 cement : 4 coarse sand) including grouting the joints with white cement and matching pigments etc., complete.					
			11.41.2	Size of Tile 60 x 60 cm Note:- The Vitrified tiles shall be double / multi charged range of tiles	608.00	sqm			
3	23	9	NSR	Supply, installation & finishing of wooden sorts flooring system consisting of the surface board of 2nd class teak wood, surface board finished with 20mm thick, 60 to 70mm width and in random length in tongue and groove	34.00	Sqm			



B-14 A, 2nd Floor
Sec-C, NOIDA
Ph. 0120-2636600

On steel work

All other condition of tender document remains unchanged.

Clawed

Head Finance
HLPPT
B-14A, Sector-62,Noida-201307

*
*
*
*
*

End of Corrigendum - 02